

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated:

No.

It is certified that an inspection team headed by Mr. Nantula Das (Fr. R/A) & Jit Majumder - (Micro Biologist)

(Name of Officers with designation) from DWS Sub-Division, Ambassa.

(Name of Department/ Office) inspected the Water Sample & Sanitary Condition of Kulai class XII School, Kulai, Dhalai Tripura.

(Name & Address of the school) on 18/05/2024 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 6 (six) month.

Signature with Seal:

Name

AMIYA RANJAN DAS.

Designation :

Assistant Engineer

Assistant Engineer of DWS Sub-Div. Ambassa
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Kulai Class XII School

Kulai, Dhalai Tripura.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Govt. of Tripura
District Level Water Testing Laboratory
DWS Sub-Division, Ambassa
Dhalai Tripura

Ref. No: -.....

Date: -.....

REPORT ON PHYSICAL, CHEMICAL & MICROBIOLOGICAL ANALYSIS OF SAMPLES

Source of Sample: **SBDTW at Kulai Class XII School, Kulai, Dhalai Tripura.**

Date & time of Collection: **15-05-2026**

Sample Collected & Supplied by: - **School Authority.**

Date & time of Received: **-15-05-2026**


Date & time of Tests: **-18-05-2026**

Sl. No.	Parameters	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Results	Remarks if any
A. Organoleptic & Physical Parameters					
01	Temperature (in degree c)			26.2	
02	Colour (in Hazen units)	05	15	05	
03	Odour	Agreeable	Agreeable	Agreeable	
04	pH Value	6.5-8.5	No relaxation	6.95	
05	Taste	Agreeable	Agreeable	Agreeable	
06	Turbidity (in NTU)	01	05	0.16	
07	Total Dissolve Solid	500	2000	120.0	
B. General Parameters Concerning Substances Undesirable in Excessive Amounts					
08	Total Alkalinity (as CaCO ₃)	200	2000	24.0	
09	Total Hardness (as CaCO ₃)	200	2000	54.0	
10	Chloride (as Cl)	250	1000	12.5	
11	Iron (as Fe)	1.0	No relaxation	0.06	
12	Calcium (as Ca)	75	200	---	
13	Magnesium (as Mg)	30	100	--	
14	Free Residual chlorine	0.2	1.0	--	
C. Microbiological Characteristic					
15	Total Coliform (in MPN/ 100ml)	-	-	NIL	
16	Fecal Coliform (in MPN/100ml)	-	-	--	
17	E. Coli (Presence or Absence)	-	-	--	

(All units are in mg/l unless mentioned otherwise.)

Analyst:


18/05/2026
Dist. Level Water Testing Lab.
Ambassa, Dhalai Tripura.


18/05/26
Assistant Engineer
DWS Sub-Division Ambassa
Dhalai Tripura

